


LEGEND

- Site Boundary —
- Existing Watermain - - -
- Proposed Watermain -100mm dia. CLASS C WATERMAIN - - -
- Proposed Fire Hydrant [H]
- Proposed Sluice Valve ⊗ SV
- Proposed Air Valve ⊗ AV

WATERMAIN NOTES

1. Watermain shall be 100mm dia. Class C uPVC
2. Connections from the Watermain shall be heavy gauge polyethylene pipe complying with BS6572 and IS134
3. Provide a min. cover od 900mm to watermain and 600mm to service pipes
4. All service connections to be provided with a stop cock
5. All pipes to be laid on a 50mm bed of fine grained material consisting of sand or gravel passing a 10mm sieve. Similar material to be placed over the pipe for a cover of 100mm.
6. Watermain to be tested to twice working pressure prior to connection to the existing main.

REVISION	NO.	DATE	BY
 Comhairle Contae Thiobraid Árann Tipperary County Council			
HOUSING SECTION CIVIC OFFICES, EMMET STREET, CLONMEL, CO. TIPPERARY S. CARR DIRECTOR OF HOUSING L. RYAN SENIOR EXECUTIVE ARCHITECT			
DRAWING TITLE: Part 8 - Proposed housing at Portroe, Nenagh, Co. Tipperary WATERMAIN LAYOUT			
DRAWN BY: MOC MAY, 2018	CHECKED BY: LR MAY, 2018	SCALE: 1: 250 @ A1	DWG No: 22/PR/P8/09/01